



DEEPA ENTERPRISES

(Testing Laboratories)

WATER, ENVIRONMENTAL TESTING, ETP, STP, DESIGN, BUILDING & ROAD MATERIAL TESTING LAB.

TEST REPORT

NO. TC541319000001290P

FARIDABAD: 44/11, ADARSH NAGAR, BALLABGARH-121004, FARIDABAD (HARYANA)
Tel. Fax: 0129-2300753, (M): 8800137739, 9958235476, 9971178062
Email: deepa_entp10@yahoo.com, info.dctlindia@gmail.com, dctl.rsv@gmail.com Website: www.dctl.in

No.-BN8970/7922:0214
DETL/F/GEN01/017

Issue Date: 16-08-2019 Request No./Date : 0987
Issue To : M/s LOKDEEP PUBLIC SCHOOL Date of sample receipt: 13-08-2019
Mohana Road, Rajiv Gandhi Marg, Yadav colony
Ballabhgarh (Hr.)-121004,India Sample drawn by : DETL
Sample particulars: Drinking water (R/o) from drinking str. Job Order No.: 6589A Sample No.: 6484

TEST RESULTS

DATE OF TESTING
13-08-2019 to 16-08-2019
PROTOCOL USED
Reference IS:10500:2012

Sample Quantity : 2.0 Lrs.
Sample drawn by: DETL Staff
Sampling Protocol:IS:3025:Pt.-I

PARAMETERS	TEST METHOD	RESULTS	UNITS	LIMITS (MAX.)	
				Desirable	Permissible
*Colour	IS: 3025:Pt-4	<5.0	Hazen	5	15
*Odour	IS: 3025:Pt-5	Unobjectionable	Unobjectionable	
*Taste	IS: 3025:Pt-7	Agreeable	Agreeable	
pH value	IS: 3025:Pt-11	6.74	...	6.5 to 8.5	
*Turbidity	IS: 3025:Pt-10	<0.1	NTU	1	5
Total hardness (as CaCO ₃)	IS: 3025:Pt-21	38.0	mg/l	200	600
Iron (as Fe)	IS: 3025:Pt-53	<0.01	mg/l	0.3	1.0
*Fluoride (as F)	IS: 3025:Pt-60	<0.1	mg/l	1.0	1.5
Chloride(as Cl)	IS: 3025:Pt-32	28.0	mg/l	250	1000
*Residual Free Chlorine	IS: 3025:Pt-26	<0.1	mg/l	0.2Min. When Chlorinated	
Total Dissolved solids	IS: 3025:Pt-16	105.0	mg/l	500	2000
Sulphate (as So ₄)	IS: 3025 Pt-24	2.4	mg/l	200	400
*Coliform Organism	IS:1622-1981	<1.1	mpn/100ml	2.0	5.0
Conductivity	IS: 3025:Pt-14	161.5	µmoh/cm	-	-

Sample Does Conforms to as per IS: 10500 w.r.t. above test results.
* Sample of water is fit for human consumption w.r.t. above test results
*Not under NABL scope
*NABL Approved and ISO Certified Lab
*ISO/IEC: 17025:2017 Certified Lab.

REMARKS:

Checked by

AUTHORISED SIGNATORY

CEO/Manager/Chief Chemist

- Sample will be retained only for one month.
- The result listed refer only to the sample and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of works is limited to invoiced amount.
- This report cannot be used as evidence in a court of law without written approval of the lab.
- Certificate shall not be reproduced except in full, without the written approval of the lab.
- Mobile No. for Sample Collection: (M) 9899206224(0) 9958235476



O/o Civil Surgeon. FARIDABAD

HYGIENE CERTIFICATE

No. SH/2019

Date: 18/7/2019

This is certified that this office has no objection issuing in Health and Hygiene Certificate to **Lokdeep Public School, Mohna road, Ballabgarh, Faridabad**. As per inspection done by **Dr. Ram Bhagat (Dy. Civil Surgeon)**, the site and building is having good hygiene condition and drinking water through RO System.

This certificate is valid upto; 31 March 2020.


Dy. Civil Surgeon
Faridabad